

FORMAT OF GRANT OF APPROVAL FOR DIESEL GENERATING SETS

HIMACHAL PRADESH
ELECTRICAL INSPECTORATE

No: HIMVINI / DG Set/SVR/ Poanta/ 2016 -

Dated:

To

M/s SVR Healthcare,
Village Barotiwala P.O. Poanta Sahib,
Tehsil Poanta Sahib Distt. Sirmour (HP).

Sub:- Inspection of Diesel Generating Set Installation under Regulation, 32 of Central Electricity Authority (Measures Relating to Safety & Electric Supply, 2010) & Approval thereof.

Reference: Your office letter No. dated 27-04-2017.

With reference to your office letter under reference, the inspection of 125 KVA, 440 volts Diesel Generating Set Installation at your premises was carried out by the undersigned on 01-06-2017. The installation work found satisfactory at the time of inspection. Hence final approval to commission the Diesel Generating Set Installation is hereby accorded subject to the condition that the consistent compliance of the relevant provisions of Central Electricity Authority (Measures Relating to Safety & Electric Supply),2010 is made for safe operation and maintenance of the installations.

Assistant Electrical Inspector,
H P Electrical Inspectorate,
Regional Office, Shimla-II.

1. Copy to the Assistant Executive Engineer, Electrical Sub Division, HPSEBL, Poanta Sahib Distt. Sirmour (HP) for information please.
2. Copy to Er. Dharamender Verma, A-Class wiring contractor, Mazra, Poanta Sahib Distt. Sirmour (HP) for information please.

Assistant Electrical Inspector,
H P Electrical Inspectorate,
Regional Office, Shimla-II.

*FORMAT OF GRANT OF APPROVAL FOR SUB STATION AND TRANSMISSION
LINES*

HIMACHAL PRADESH
ELECTRICAL INSPECTORATE

No: HIMVINI / HVI/SVR/ Poanta/ 2016 -

Dated:

To

M/s SVR Healthcare,
Village Barotiwala P.O. Poanta Sahib,
Tehsil Poanta Sahib Distt. Sirmour (HP).

Sub:- Inspection of Electrical Installation under Regulation, 43 of
Central Electricity Authority (Measures Relating to Safety &
Electric Supply, 2010) & Approval thereof.

Reference: Your office letter No. dated 27-
04-2017.

With reference to your office letter under reference, the
inspection of following high voltage electrical installations was carried out by
the undersigned on dated 02-06-2017:

1. 63 KVA, 11/0.4 KV sub station Mehra Basti.
2. 11 KV HT Line to above sub station.

The installations work found satisfactory at the time of inspection.
Hence approval to energise the Installation is hereby accorded subject to the
condition that the consistent compliance of the relevant provisions of Central
Electricity Authority (Measures Relating to Safety & Electric Supply),2010 is
made for safe operation and maintenance of the installations.

Assistant Electrical Inspector,
H P Electrical Inspectorate,
Regional Office, Shimla-II.

1. Copy to the Sr. Executive Engineer, Electrical Division, HPSEBL,
Poanta Sahib Distt. Sirmour (HP) for information please.
2. Copy to the Assistant Executive Engineer, Electrical Sub Division,
HPSEBL, Poanta Sahib Distt. Sirmour (HP) for information please.

Assistant Electrical Inspector,
H P Electrical Inspectorate,
Regional Office, Shimla-II.

**FORMAT OF GRANT OF APPROVAL FOR FOR MULTISTORIED
BUILDINGS MORE THAN 15 MTR. IN HEIGHT**

HIMACHAL PRADESH
ELECTRICAL INSPECTORATE

No: HIMVINI / HVI/SVR/ Poanta/ 2016 -

Dated:

To

M/s SVR Healthcare,
Village Barotiwala P.O. Poanta Sahib,
Tehsil Poanta Sahib Distt. Sirmour (HP).

Sub:- Inspection of Electrical Installation under Regulation, 36 of
Central Electricity Authority (Measures Relating to Safety &
Electric Supply, 2010) & Approval thereof.

Reference: Your office letter No. dated 27-
04-2017.

With reference to your office letter under reference, the
inspection of following electrical installations was carried out by the
undersigned on dated 02-06-2017:

1. 63 KVA, 11/0.4 KV sub station Mehra Basti.
2. 100 KVA, 11/0.4 KV sub station Behind Tapan Motors.

The installations work found satisfactory at the time of inspection.
Hence approval to energise the Installation is hereby accorded subject to the
condition that the consistent compliance of the relevant provisions of Central
Electricity Authority (Measures Relating to Safety & Electric Supply),2010 is
made for safe operation and maintenance of the installations.

Assistant Electrical Inspector,
H P Electrical Inspectorate,
Regional Office, Shimla-II.

1. Copy to the Sr. Executive Engineer, Electrical Division, HPSEBL,
Poanta Sahib Distt. Sirmour (HP) for information please.
2. Copy to the Assistant Executive Engineer, Electrical Sub Division,
HPSEBL, Poanta Sahib Distt. Sirmour (HP) for information please.

Assistant Electrical Inspector,
H P Electrical Inspectorate,
Regional Office, Shimla-II.